

Model 1384-B



Superior Fire Suppression for Commercial Occupancies Where Residential Style Appliances Are in Use

Over 400,000 systems installed
and supported by our distributors
worldwide since 1985



GUARDIAN

SAFETY SOLUTIONS INTERNATIONAL, INC.

www.guardianssi.com

Specifications:

Model 1384-B

Operation: Mechanical

Coverage:

Electric and Gas Ranges may not exceed a width of 36" wide x 24" deep or 864 sqi.

Hood:

Any standard residential hood with a single light and fan in the center that meets the same range size requirements. The bottom of the hood cannot exceed 30" from the range top.

Nozzles:

The nozzle tip must be at least 18" above the range with a maximum of 28".

Fusible Links:

Distance from the detection links to the range top shall not exceed 26 1/2". Globe 'B' links are used.

Fuel Shutoff:

Each system is UL Listed with a gas or electric fuel shutoff.

Pre-Assembled • Pre-Engineered

When a fire occurs, one or more of the four fusible links will separate, releasing the cable tension, which discharges the system.

Selective code officials recommend and accept the Guardian System for commercial occupancies where residential appliances are in use.

www.guardianssi.com



UL Subject 300A, UL 299, UL 864, NFPA 10
See ICC-ES Listing, No. 1166 at www.icc-es-pmg.org

